

No. 93

FEE.....

THE COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

TOWN OF EDGARTOWN

Application for Disposal Works Construction Permit

Application is hereby made for a Permit to Construct () or Repair () an Individual Sewage Disposal System at:

DODGER'S HOLE LCR 114059, LOT 304, ASSE. PER. 10-12
Location - Address or Lot No.
H. H. HSIEH % WATERMARK HOMES P.O. Box 1414 EDGARTOWN, MA. 02539
Owner Address

Installer Address 21,300 Sq. feet
Type of Building Size Lot
Dwelling - No. of Bedrooms Four Expansion Attic () Garbage Grinder ()
Other - Type of Building No. of persons Showers () - Cafeteria ()
Other fixtures

Design Flow 55 gallons per person per day. Total daily flow 440 gallons.
Septic Tank - Liquid capacity 1,000 gallons Length Width Diameter Depth 48"
Disposal Trench - No. Width Total Length Total leaching area 216 sq. ft.
Seepage Pit No. ONE Diameter 8-6" Depth below inlet 6-0" Total leaching area 216 sq. ft.
Other Distribution box () Dosing tank ()
Percolation Test Results Performed by SCHOFIELD BROTHERS, INC. Date 4/27/1989
Test Pit No. 1 2 minutes per inch Depth of Test Pit 11-6" Depth to ground water NONE ENC
Test Pit No. 2 minutes per inch Depth of Test Pit Depth to ground water

Description of Soil 0-6" TOPSOIL
6"-42" SILTY SAND SUBSOIL
42"-138" MEDIUM SAND
Nature of Repairs or Alterations - Answer when applicable

Agreement:
The undersigned agrees to install the aforescribed Individual Sewage Disposal System in accordance with the provisions of TITLE 5 of the State Sanitary Code - The undersigned further agrees not to place the system in operation until a Certificate of Compliance has been issued by the board of health.

Signed Douglas A. Hartnett - Agent 8/22/89
Application Approved By A. Cook Date 9-12-89
HEALTH AGENT

Application Disapproved for the following reasons:
Date

Permit No. Issued Date

THE COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

Certificate of Compliance

THIS IS TO CERTIFY, That the Individual Sewage Disposal System constructed () or Repaired () by K. PETERS Installer at AP 10-12 (11-5-11) has been installed in accordance with the provisions of TITLE 5 of The State Sanitary Code as described in the application for Disposal Works Construction Permit No. dated 7-12-87

THE ISSUANCE OF THIS CERTIFICATE SHALL NOT BE CONSTRUED AS A GUARANTEE THAT THE SYSTEM WILL FUNCTION SATISFACTORY.

DATE 11-8-70 Inspector J. Cook

THE COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

No. 93 Town Edg OF

FEE 50.-

Disposal Works Construction Permit

Permission is hereby granted H. H. Hsieh % Watermark Homes to Construct () or Repair () an Individual Sewage Disposal System at No. Lot 384 Dodger's Hole AP 10-12 4 bedroom as shown on the application for Disposal Works Construction Permit No. 93 Dated 8-29-89

DATE 9-12-89 A. Cook Board of Health
HEALTH AGENT

CHECK OR FILL IN WHERE APPLICABLE