



Commonwealth of Massachusetts

PAID
1417

RECEIVED

DEC 06 2022

OBBOD OF HEALTH

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

21 Hudson Ave

21-16

Property Address

C/O Timothy J Dyke

Owner's Name

Oak Bluffs

MA
State

02557
Zip Code

11/19/22
Date of Inspection

City/Town

Owner information is required for every page.

Inspection results must be submitted on this form. Inspection forms may not be altered in any way. Please see completeness checklist at the end of the form.

Important: When filling out forms on the computer, use only the tab key to move your cursor - do not use the return key.



A. Inspector Information

Matthew Parker

Name of Inspector

Parker Septic & Drain LLC

Company Name

16 Sea Glen Rd

Company Address

Oak Bluffs

MA
State

02557
Zip Code

City/Town

(774) 563-5548

SI 14449

Telephone Number

License Number

B. Certification

I certify that: I am a DEP approved system inspector in full compliance with Section 15.340 of Title 5 (310 CMR 15.000); I have personally inspected the sewage disposal system at the property address listed above; the information reported below is true, accurate and complete as of the time of my inspection; and the inspection was performed based on my training and experience in the proper function and maintenance of on-site sewage disposal systems. After conducting this inspection I have determined that the system:

- Passes
- Conditionally Passes
- Needs Further Evaluation by the Local Approving Authority
- Fails


Inspector's Signature

11/19/22
Date

The system inspector shall submit a copy of this inspection report to the Approving Authority (Board of Health or DEP) within 30 days of completing this inspection. If the system has a design flow of 10,000 gpd or greater, the inspector and the system owner shall submit the report to the appropriate regional office of the DEP. The original form should be sent to the system owner and copies sent to the buyer, if applicable, and the approving authority.

Please note: This report only describes conditions at the time of inspection and under the conditions of use at that time. This inspection does not address how the system will perform in the future under the same or different conditions of use.



Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

21 Hudson Ave 21-16
 Property Address

C/O Timothy J Dyke
 Owner's Name

Oak Bluffs MA 02557 11/19/22
 City/Town State Zip Code Date of Inspection

Owner information is required for every page.

C. Inspection Summary

Inspection Summary: Complete 1, 2, 3, or 5 and all of 4 and 6.

1) System Passes:

I have not found any information which indicates that any of the failure criteria described in 310 CMR 15.303 or in 310 CMR 15.304 exist. Any failure criteria not evaluated are indicated below.

Comments:

System was found in proper working order at the time of inspection. The tank and pit number one should be pumped for maintenance purposee. Pit two was found bone dry at the time of inspection.

2) System Conditionally Passes:

One or more system components as described in the "Conditional Pass" section need to be replaced or repaired. The system, upon completion of the replacement or repair, as approved by the Board of Health, will pass.

Check the box for "yes", "no" or "not determined" (Y, N, ND) for the following statements. If "not determined," please explain.

The septic tank is metal and over 20 years old* or the septic tank (whether metal or not) is structurally unsound, exhibits substantial infiltration or exfiltration or tank failure is imminent. System will pass inspection if the existing tank is replaced with a complying septic tank as approved by the Board of Health.

* A metal septic tank will pass inspection if it is structurally sound, not leaking and if a Certificate of Compliance indicating that the tank is less than 20 years old is available.

Y N ND (Explain below):



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

21 Hudson Ave

21-16

Property Address

C/O Timothy J Dyke

Owner's Name

Oak Bluffs

MA

02557

11/19/22

City/Town

State

Zip Code

Date of Inspection

Owner information is required for every page.

C. Inspection Summary (cont.)

2) System Conditionally Passes (cont.):

[] Pump Chamber pumps/alarms not operational. System will pass with Board of Health approval if pumps/alarms are repaired.

[] Observation of sewage backup or break out or high static water level in the distribution box due to broken or obstructed pipe(s) or due to a broken, settled or uneven distribution box. System will pass inspection if (with approval of Board of Health):

[] broken pipe(s) are replaced [] Y [] N [] ND (Explain below):

[] obstruction is removed [] Y [] N [] ND (Explain below):

[] distribution box is leveled or replaced [] Y [] N [] ND (Explain below):

[] The system required pumping more than 4 times a year due to broken or obstructed pipe(s). The system will pass inspection if (with approval of the Board of Health):

[] broken pipe(s) are replaced [] Y [] N [] ND (Explain below):

[] obstruction is removed [] Y [] N [] ND (Explain below):

3) Further Evaluation is Required by the Board of Health:

[] Conditions exist which require further evaluation by the Board of Health in order to determine if the system is failing to protect public health, safety or the environment.

a. System will pass unless Board of Health determines in accordance with 310 CMR 15.303(1)(b) that the system is not functioning in a manner which will protect public health, safety and the environment:



Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

21 Hudson Ave 21-16
 Property Address
 C/O Timothy J Dyke
 Owner's Name
 Oak Bluffs MA 02557 11/19/22
 City/Town State Zip Code Date of Inspection

Owner information is required for every page.

C. Inspection Summary (cont.)

- Cesspool or privy is within 50 feet of a surface water
- Cesspool or privy is within 50 feet of a bordering vegetated wetland or a salt marsh

b. System will fail unless the Board of Health (and Public Water Supplier, if any) determines that the system is functioning in a manner that protects the public health, safety and environment:

- The system has a septic tank and soil absorption system (SAS) and the SAS is within 100 feet of a surface water supply or tributary to a surface water supply.
- The system has a septic tank and SAS and the SAS is within a Zone 1 of a public water supply.
- The system has a septic tank and SAS and the SAS is within 50 feet of a private water supply well.
- The system has a septic tank and SAS and the SAS is less than 100 feet but 50 feet or more from a private water supply well**.

Method used to determine distance: _____

** This system passes if the well water analysis, performed at a DEP certified laboratory, for fecal coliform bacteria indicates absent and the presence of ammonia nitrogen and nitrate nitrogen is equal to or less than 5 ppm, provided that no other failure criteria are triggered. A copy of the analysis must be attached to this form.

c. Other:

4) System Failure Criteria Applicable to All Systems:

You must indicate "Yes" or "No" to each of the following for all inspections:

- | Yes | No | |
|--------------------------|-------------------------------------|---|
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Backup of sewage into facility or system component due to overloaded or clogged SAS or cesspool |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Discharge or ponding of effluent to the surface of the ground or surface waters due to an overloaded or clogged SAS or cesspool |



Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

21 Hudson Ave 21-16
 Property Address
 C/O Timothy J Dyke
 Owner's Name
 Oak Bluffs MA 02557 11/19/22
 City/Town State Zip Code Date of Inspection

Owner information is required for every page.

C. Inspection Summary (cont.)

4) System Failure Criteria Applicable to All Systems: (cont.)

- | Yes | No | |
|--------------------------|-------------------------------------|---|
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Static liquid level in the distribution box above outlet invert due to an overloaded or clogged SAS or cesspool |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Liquid depth in cesspool is less than 6" below invert or available volume is less than 1/2 day flow |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Required pumping more than 4 times in the last year NOT due to clogged or obstructed pipe(s). Number of times pumped: _____. |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Any portion of the SAS, cesspool or privy is below high ground water elevation. |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Any portion of cesspool or privy is within 100 feet of a surface water supply or tributary to a surface water supply. |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Any portion of a cesspool or privy is within a Zone 1 of a public water supply well. |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Any portion of a cesspool or privy is within 50 feet of a private water supply well. |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Any portion of a cesspool or privy is less than 100 feet but greater than 50 feet from a private water supply well with no acceptable water quality analysis. [This system passes if the well water analysis, performed at a DEP certified laboratory, for fecal coliform bacteria indicates absent and the presence of ammonia nitrogen and nitrate nitrogen is equal to or less than 5 ppm, provided that no other failure criteria are triggered. A copy of the analysis and chain of custody must be attached to this form.] |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | The system is a cesspool serving a facility with a design flow of 2000 gpd-10,000 gpd. |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | The system fails. I have determined that one or more of the above failure criteria exist as described in 310 CMR 15.303, therefore the system fails. The system owner should contact the Board of Health to determine what will be necessary to correct the failure. |

5) Large Systems: To be considered a large system the system must serve a facility with a design flow of 10,000 gpd to 15,000 gpd.

For large systems, you must indicate either "yes" or "no" to each of the following, in addition to the questions in Section C.4.

- | Yes | No | |
|--------------------------|--------------------------|--|
| <input type="checkbox"/> | <input type="checkbox"/> | the system is within 400 feet of a surface drinking water supply |
| <input type="checkbox"/> | <input type="checkbox"/> | the system is within 200 feet of a tributary to a surface drinking water supply |
| <input type="checkbox"/> | <input type="checkbox"/> | the system is located in a nitrogen sensitive area (Interim Wellhead Protection Area – IWPA) or a mapped Zone II of a public water supply well |



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

21 Hudson Ave

21-16

Property Address

C/O Timothy J Dyke

Owner's Name

Oak Bluffs

MA

02557

11/19/22

City/Town

State

Zip Code

Date of Inspection

Owner information is required for every page.

C. Inspection Summary (cont.)

If you have answered "yes" to any question in Section C.5 the system is considered a significant threat, or answered "yes" to any question in Section C.4 above the large system has failed. The owner or operator of any large system considered a significant threat under Section C.5 or failed under Section C.4 shall upgrade the system in accordance with 310 CMR 15.304. The system owner should contact the appropriate regional office of the Department.

6. You must indicate "yes" or "no" for each of the following for all inspections:

Yes No

- Checkboxes and questions regarding pumping information, system components, water volumes, built plans, sewage back up, break out, system components location, septic tank manholes, facility owner information, and field determination.



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

21 Hudson Ave 21-16

Property Address

C/O Timothy J Dyke

Owner's Name

Oak Bluffs MA 02557 11/19/22

City/Town

State

Zip Code

Date of Inspection

Owner information is required for every page.

D. System Information

1. Residential Flow Conditions:

Number of bedrooms (design): 8 Number of bedrooms (actual): 8

DESIGN flow based on 310 CMR 15.203 (for example: 110 gpd x # of bedrooms): 1102 GPD

Description:

Information taken from best available data on file at local BOH offices

Number of current residents: Unknown

Does residence have a garbage grinder? [] Yes [] No

Does residence have a water treatment unit? [] Yes [x] No

If yes, discharges to:

Is laundry on a separate sewage system? (Include laundry system inspection information in this report.) [] Yes [x] No

Laundry system inspected? [] Yes [x] No

Seasonal use? [] Yes [x] No

Water meter readings, if available (last 2 years usage (gpd)):

Detail:

Unable to enter the residence to check plumbing.

Sump pump? [] Yes [] No

Last date of occupancy: Unknown Date



Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

21 Hudson Ave 21-16
 Property Address

C/O Timothy J Dyke
 Owner's Name

Oak Bluffs	MA	02557	11/19/22
City/Town	State	Zip Code	Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

2. Commercial/Industrial Flow Conditions:

Type of Establishment: _____

Design flow (based on 310 CMR 15.203): _____
 Gallons per day (gpd)

Basis of design flow (seats/persons/sq.ft., etc.): _____

Grease trap present? Yes No

Water treatment unit present? Yes No

If yes, discharges to: _____

Industrial waste holding tank present? Yes No

Non-sanitary waste discharged to the Title 5 system? Yes No

Water meter readings, if available: _____

Last date of occupancy/use: _____
 Date

Other (describe below):

3. Pumping Records:

Source of information: _____

Was system pumped as part of the inspection? Yes No

If yes, volume pumped: _____
 gallons

How was quantity pumped determined? _____

Reason for pumping: _____



Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

21 Hudson Ave 21-16
 Property Address

C/O Timothy J Dyke
 Owner's Name

Oak Bluffs	MA	02557	11/19/22
City/Town	State	Zip Code	Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

4. Type of System:

- Septic tank, distribution box, soil absorption system
- Single cesspool
- Overflow cesspool
- Privy
- Shared system (yes or no) (if yes, attach previous inspection records, if any)
- Innovative/Alternative technology. Attach a copy of the current operation and maintenance contract (to be obtained from system owner) and a copy of latest inspection of the I/A system by system operator under contract
- Tight tank. Attach a copy of the DEP approval.
- Other (describe):

Approximate age of all components, date installed (if known) and source of information:

4/2/87 Disposal Works Construction Permit

Were sewage odors detected when arriving at the site? Yes No

5. Building Sewer (locate on site plan):

Depth below grade: 2.5'
feet

Material of construction:

cast iron 40 PVC other (explain): _____

Distance from private water supply well or suction line: 100'+
feet

Comments (on condition of joints, venting, evidence of leakage, etc.):

Building Sewer appears to be in sound condition at the time of inspection.



Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

21 Hudson Ave 21-16
 Property Address

C/O Timothy J Dyke
 Owner's Name

Oak Bluffs MA 02557 11/19/22
 City/Town State Zip Code Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

6. **Septic Tank** (locate on site plan):

Depth below grade: 2'
feet

Material of construction:

- concrete metal fiberglass polyethylene other (explain)

If tank is metal, list age: _____ years

Is age confirmed by a Certificate of Compliance? (attach a copy of certificate) Yes No

Dimensions: 1500 Gallons

Sludge depth: 6"

Distance from top of sludge to bottom of outlet tee or baffle 2'

Scum thickness 2"

Distance from top of scum to top of outlet tee or baffle 8"

Distance from bottom of scum to bottom of outlet tee or baffle 16"

How were dimensions determined? Tape

Comments (on pumping recommendations, inlet and outlet tee or baffle condition, structural integrity, liquid levels as related to outlet invert, evidence of leakage, etc.):
 System should receive maintenance pumping due to high solids found at the time of inspection.



Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

21 Hudson Ave 21-16
 Property Address

C/O Timothy J Dyke
 Owner's Name

Oak Bluffs	MA	02557	11/19/22
City/Town	State	Zip Code	Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

7. **Grease Trap** (locate on site plan):

Depth below grade: _____ feet

Material of construction:

concrete metal fiberglass polyethylene other (explain):

Dimensions: _____

Scum thickness _____

Distance from top of scum to top of outlet tee or baffle _____

Distance from bottom of scum to bottom of outlet tee or baffle _____

Date of last pumping: _____ Date

Comments (on pumping recommendations, inlet and outlet tee or baffle condition, structural integrity, liquid levels as related to outlet invert, evidence of leakage, etc.):

8. **Tight or Holding Tank** (tank must be pumped at time of inspection) (locate on site plan):

Depth below grade: _____

Material of construction:

concrete metal fiberglass polyethylene other (explain):

Dimensions: _____

Capacity: _____ gallons

Design Flow: _____ gallons per day



Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

21 Hudson Ave 21-16
 Property Address

C/O Timothy J Dyke
 Owner's Name

Oak Bluffs	MA	02557	11/19/22
City/Town	State	Zip Code	Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

8. Tight or Holding Tank (cont.)

Alarm present: Yes No

Alarm level: _____ Alarm in working order: Yes No

Date of last pumping: _____
 Date

Comments (condition of alarm and float switches, etc.):

* Attach copy of current pumping contract (required). Is copy attached? Yes No

9. Distribution Box (if present must be opened) (locate on site plan):

Depth of liquid level above outlet invert N/A

Comments (note if box is level and distribution to outlets equal, any evidence of solids carryover, any evidence of leakage into or out of box, etc.):



Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

21 Hudson Ave 21-16
 Property Address

C/O Timothy J Dyke
 Owner's Name

Oak Bluffs	MA	02557	11/19/22
City/Town	State	Zip Code	Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

10. Pump Chamber (locate on site plan):

Pumps in working order: Yes No*

Alarms in working order: Yes No*

Comments (note condition of pump chamber, condition of pumps and appurtenances, etc.):

* If pumps or alarms are not in working order, system is a conditional pass.

11. Soil Absorption System (SAS) (locate on site plan, excavation not required):

If SAS not located, explain why:

Type:

- leaching pits number: 2
- leaching chambers number: _____
- leaching galleries number: _____
- leaching trenches number, length: _____
- leaching fields number, dimensions: _____
- overflow cesspool number: _____
- innovative/alternative system

Type/name of technology: _____



Commonwealth of Massachusetts
Title 5 Official Inspection Form
Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

21 Hudson Ave 21-16
 Property Address

C/O Timothy J Dyke
 Owner's Name

Oak Bluffs	MA	02557	11/19/22
City/Town	State	Zip Code	Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

11. Soil Absorption System (SAS) (cont.)

Comments (note condition of soil, signs of hydraulic failure, level of ponding, damp soil, condition of vegetation, etc.):

Pit number one was working at 90% capacity and should be pumped due to carryover found. Pit two was found bone dry at the time of inspection.

12. Cesspools (cesspool must be pumped as part of inspection) (locate on site plan):

Number and configuration _____

Depth – top of liquid to inlet invert _____

Depth of solids layer _____

Depth of scum layer _____

Dimensions of cesspool _____

Materials of construction _____

Indication of groundwater inflow Yes No

Comments (note condition of soil, signs of hydraulic failure, level of ponding, condition of vegetation, etc.):



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

21 Hudson Ave 21-16
Property Address

C/O Timothy J Dyke
Owner's Name

Oak Bluffs	MA	02557	11/19/22
City/Town	State	Zip Code	Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

13. Privy (locate on site plan):

Materials of construction: _____

Dimensions _____

Depth of solids _____

Comments (note condition of soil, signs of hydraulic failure, level of ponding, condition of vegetation, etc.):



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

21 Hudson Ave

21-16

Property Address

C/O Timothy J Dyke

Owner's Name

Owner information is required for every page.

Oak Bluffs

MA

02557

11/19/22

City/Town

State

Zip Code

Date of Inspection

D. System Information (cont.)

14. Sketch Of Sewage Disposal System:

Provide a view of the sewage disposal system, including ties to at least two permanent reference landmarks or benchmarks. Locate all wells within 100 feet. Locate where public water supply enters the building. Check one of the boxes below:

- hand-sketch in the area below
- drawing attached separately



Commonwealth of Massachusetts
Title 5 Official Inspection Form
 Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

21 Hudson Ave 21-16
 Property Address

C/O Timothy J Dyke
 Owner's Name

Oak Bluffs MA 02557 11/19/22
 City/Town State Zip Code Date of Inspection

Owner information is required for every page.

D. System Information (cont.)

15. Site Exam:

- Check Slope
- Surface water
- Check cellar
- Shallow wells

Estimated depth to high ground water: 25' +/-
feet

Please indicate all methods used to determine the high ground water elevation:

- Obtained from system design plans on record
 If checked, date of design plan reviewed: 1987
Date
- Observed site (abutting property/observation hole within 150 feet of SAS)
- Checked with local Board of Health - explain:
Previous inspection report
- Checked with local excavators, installers - (attach documentation)
- Accessed USGS database - explain:

You **must** describe how you established the high ground water elevation:

this site resides at an elevation of appox 30' MSL ground water studys indicate ground water at an elevation of appox 5' MSL

Before filing this Inspection Report, please see Report Completeness Checklist on next page.



Commonwealth of Massachusetts

Title 5 Official Inspection Form

Subsurface Sewage Disposal System Form - Not for Voluntary Assessments

21 Hudson Ave

21-16

Property Address

C/O Timothy J Dyke

Owner's Name

Oak Bluffs

MA

02557

11/19/22

City/Town

State

Zip Code

Date of Inspection

Owner information is required for every page.

E. Report Completeness Checklist

Complete all applicable sections of this form inclusive of:

A. Inspector Information: Complete all fields in this section.

B. Certification: Signed & Dated and 1, 2, 3, or 4 checked

C. Inspection Summary:

1, 2, 3, or 5 completed as appropriate


4 (Failure Criteria) and 6 (Checklist) completed

D. System Information:

For 8: Tight/Holding Tank – Pumping contract attached

For 14: Sketch of Sewage Disposal System drawn on pg. 16 or attached

For 15: Explanation of estimated depth to high groundwater included



KEY:
A1 17'
A2 28.5'
A3 73.5'
B1 15'
B2 13'
B3 47.5'
C3 15'