



DESCRIPTION	ELEVATION DESIGN	ELEVATION AS-BUILT	SWING TIE			
			A	B	C	D
TOP OF FOUNDATION	105.05	EXISTING				
4" INV. OUT OF HOUSE	99.60	100.6±				
TOP OF FOUNDATION (POOL HOUSE)	101.0	102.94				
4" INV. OUT OF POOL HOUSE	97.79	100.56				
1 4" INV. AT SEPTIC TANK 1 (IN)	99.28	100.16	20.9	18.6		
2 4" INV. AT SEPTIC TANK 1 (OUT)	99.03	99.94	27.2	25.0		
3 4" INV. AT SEPTIC TANK 2 (IN)	97.59	98.18			13.9	16.5
4 4" INV. AT SEPTIC TANK 2 (OUT)	97.34	98.00			13.9	23.4
5 4" INV. AT D-BOX (IN)	97.44	96.94	76.8	79.1		
4" INV. AT D-BOX (OUT)	97.27	96.81				
4" INV INTO QUICK-4 CHAMBER	97.17	96.66				
BOTTOM OF QUICK-4 CHAMBER	96.50	95.99				
6 INSPECTION PORT			75.8	89.1		
GROUND WATER	89.5	89.5				

NOTES:

1. WATER PURIFICATION SYSTEM'S BACKWASH SHALL BE PROHIBITED FROM DISCHARGING INTO THE SEPTIC TANK AND SHALL DISCHARGE TO A DRYWELL OR TO THE GROUND IN ACCORDANCE WITH 310 CMR 15.004 (8). THE BACKWASH IS NOT TO BE DISCHARGED INTO OR IN THE DIRECTION OF THE SEPTIC SYSTEM.
2. THE SEPTIC SYSTEM OWNER SHALL HAVE THE SEPTIC TANK(S) AND OUTLET FILTER(S) INSPECTED ANNUALLY AND CLEANED AND PUMPED AS NECESSARY.
3. OPEN HOLE INSPECTION PERFORMED BY THE OAK BLUFFS BOARD OF HEALTH.
4. FOUNDATION AS-BUILT AND POOL LOCATION PROVIDED BY ZENITH LAND SURVEYORS, LLC.

I HEREBY CERTIFY THAT THE SUBSURFACE DISPOSAL SYSTEM HAS BEEN CONSTRUCTED IN COMPLIANCE WITH 310 CMR 15.000, THE APPROVED DESIGN PLANS AND ALL LOCAL REQUIREMENTS AND THAT ANY CHANGES TO THE DESIGN PLANS HAVE BEEN REFLECTED ON THE AS-BUILT WHICH IS HEREBY BEING SUBMITTED TO THE OAK BLUFFS BOARD OF HEALTH.



RECEIVED
AUG 21 2023
OB BD OF HEALTH

NYLES ZAGER, P.E.

DATE

SHEET NAME:
SUBSURFACE SEWAGE DISPOSAL SYSTEM AS-BUILT

PROJECT SITE:
**3 MAYHEW WAY 29-187
OAK BLUFFS, MASSACHUSETTS**

CLIENT INFO:
**VINEYARD POOL & SPA
18 E LINE ROAD
EDGARTOWN, MA 02539**

DRAWN BY:
WBC

DESIGNED BY:
WBC

CHECKED BY:
NCZ

APPROVED BY:
NCZ

GRAPHICS SCALE
1 inch = 30 feet

DATE:
7-18-23

PROJECT NUMBER
0950-01-01

SHEET ID
SEPTIC AS-BUILT

ZCE
ZENITH CONSULTING ENGINEERS, LLC
3 MAIN STREET LAKEVILLE, MA 02347
PHONE: (508) 947-4208

FILE COPY